

**OPERATOR QUALIFICATION  
FIELD INSPECTION PROTOCOL FORM**

|  |                                |
|--|--------------------------------|
| <b>Inspection Date(s):</b>               | 8 July—12 July 2013            |
| <b>Name of Operator:</b>                 | Tidewater Terminal Company     |
| <b>Operator ID (OPID):</b>               | 31051                          |
| <b>Inspection Location(s):</b>           | Snake River Terminal, Pasco WA |
| <b>Supervisor(s) Contacted:</b>          | Ron McClary, Mark Davis        |
| <b># Qualified Employees Observed:</b>   | 3                              |
| <b># Qualified Contractors Observed:</b> | 0                              |

| <b>Individual Observed</b> | <b>Title/Organization</b>   | <b>Phone Number</b> | <b>Email Address</b> |
|----------------------------|-----------------------------|---------------------|----------------------|
| Tim Berry                  | Maintenance Leadman         | (509)727-0797       |                      |
| Damon Remus                | Terminal Operator/Tankerman | (509)727-1585       |                      |
| George Robinson            | Maintenance/Tanker man      |                     |                      |
|                            |                             |                     |                      |

*To add rows, press TAB with cursor in last cell.*

| <b>PHMSA/State Representative</b> | <b>Region/State</b> | <b>Email Address</b> |
|-----------------------------------|---------------------|----------------------|
| Dennis Ritter                     | WA                  | dritter@utc.wa.gov   |
|                                   |                     |                      |
|                                   |                     |                      |

*To add rows, press TAB with cursor in last cell.*

**Remarks:**

A table for recording specific tasks performed and the individuals who performed the tasks is on the last page of this form. This form is to be uploaded on to the OQBD for the appropriate operator, then imported into the file.

**9.01 Covered Task Performance**

Verify the qualified individuals performed the observed covered tasks in accordance with the operator’s procedures or operator approved contractor procedures.

| <b>9.01 Inspection Results</b><br>(type an X in exactly one cell below) |   | <b>Inspection Notes</b>      |
|---|---|------------------------------|
| <b>X</b>  | <b>No Issue Identified</b>                  | Covered tasks as noted below |
|   | <b>Potential Issue Identified (explain)</b> |                              |
|   | <b>N/A (explain)</b>                        |                              |
|   | <b>Not Inspected</b>                        |                              |

**9.02 Qualification Status**

Verify the individuals performing the observed covered tasks are currently qualified to perform the covered tasks.

| <b>9.02 Inspection Results</b><br>(type an X in exactly one cell below) |   | <b>Inspection Notes</b> |
|---|---|-------------------------|
| <b>X</b>  | <b>No Issue Identified</b>                  |                         |
|   | <b>Potential Issue Identified (explain)</b> |                         |
|   | <b>N/A (explain)</b>                        |                         |
|   | <b>Not Inspected</b>                        |                         |
|   |   |                         |

**9.03 Abnormal Operating Condition Recognition and Reaction**

Verify the individuals performing covered tasks are cognizant of the AOCs that are applicable to the tasks observed.

| <b>9.03 Inspection Results</b><br>(type an X in exactly one cell below) |   | <b>Inspection Notes</b>   |
|---|---|---|
| <b>X</b>  | <b>No Issue Identified</b>                  | Rectifier—tripped breakers, loose connections, bugs, check volts and amps—compare with actual. Employee knew what to look for and how to react. |
|   | <b>Potential Issue Identified (explain)</b> |   |
|   | <b>N/A (explain)</b>                        |   |
|   | <b>Not Inspected</b>                        |   |

**9.04 Verification of Qualification**

Verify the qualification records are current, and ensure the personal identification of all individuals performing covered tasks are checked, prior to task performance.

| <b>9.04 Inspection Results</b><br>(type an X in exactly one cell below) |   | <b>Inspection Notes</b> |
|---|---|-------------------------|
| <b>X</b>  | <b>No Issue Identified</b>                  |                         |
|   | <b>Potential Issue Identified (explain)</b> |                         |
|   | <b>N/A (explain)</b>                        |                         |
|   | <b>Not Inspected</b>                        |                         |

**9.05 Program Inspection Deficiencies**

Have potential issues identified by the headquarters inspection process been corrected at the operational level?

| <b>9.05 Inspection Results</b><br>(type an X in exactly one cell below) |   | <b>Inspection Notes</b> |
|---|---|-------------------------|
| <b>X</b>  | <b>No Issue Identified</b>                  |                         |
|   | <b>Potential Issue Identified (explain)</b> |                         |
|   | <b>N/A (explain)</b>                        |                         |
|   | <b>Not Inspected</b>                        |                         |

**Field Inspection Notes**

The following table is provided for recording the covered tasks observed and the individuals performing those tasks.

| No | Task Name                        | Name/ID of Individual Observed |                           |                           | Comments   |
|----|----------------------------------|--------------------------------|---------------------------|---------------------------|--|
|    |                                  | Tim Berry                      | George Robinson           | Damon Remus               |  |
|    |                                  | Correct Performance (Y/N)      | Correct Performance (Y/N) | Correct Performance (Y/N) |  |
| 1  | Rectifier Check                  | Y                              |                           |                           |  |
| 2  | Pressure relief                  | Y                              | Y                         |                           |  |
| 3  | Start up-batch flow              |                                |                           | Y                         | Pump seals, valve packing, leaks, panel board status |
| 4  | Pipe to soil                     | Y                              |                           |                           |  |
| 5  | Block Valve Operation            | Y                              |                           | Y                         |  |
| 6  | Patrolling                       | Y                              |                           |                           |  |
| 7  | isolation                        | Y                              |                           |                           |  |
| 8  | Monthly breakout tank inspection | Y                              |                           |                           |  |

**Operations and Maintenance Records Review**

If performing an operations and maintenance records review in the course of your inspection, please review a sample of the qualifications of the individuals performing those O&M tasks that are covered under Operator Qualification and check the records for compliance to 192.807 or 195.507.

|                    |   |      |        |             |
|--------------------|---|------|--------|-------------|
| 192.807 or 195.507 | Records supporting an individual’s current qualifications shall be maintained while the individual is performing the covered task. Records of prior qualification and records of individuals no longer performing covered tasks shall be retained for a period of five years. | Sat. | Unsat. | Not Checked |
|                    |   | X    |        |             |

*PHMSA (OQ) Field Inspection Form 15 (Rev. 4) May 17, 2007*

|  |           |  |  |  |
|--|-----------|--|--|--|
|  | Comments: |  |  |  |
|--|-----------|--|--|--|